

ケーブルラベル	結果	長さ (m)	NEXTマージン (dB)	規格	日時
CU A-1	✓	2.1	13.6	TIA - Cat 6A Channel	2014/12/09 13:00:28
CU A-2	✓	2.1	12.3	TIA - Cat 6A Channel	2014/12/10 13:11:38
CU A-3	✓	2.1	13.5	TIA - Cat 6A Channel	2014/12/10 13:12:38
CU A-4	✓	2.1	13.8	TIA - Cat 6A Channel	2014/12/16 9:59:02
CU A-5	✓	2.1	12.4	TIA - Cat 6A Channel	2014/12/16 10:00:50
CU A-6	✓	2.1	13.1	TIA - Cat 6A Channel	2014/12/18 9:51:09
CU A-7	✓	2	12.5	TIA - Cat 6A Channel	2014/12/18 9:52:04
CU A-8	✓	2.1	13.2	TIA - Cat 6A Channel	2014/12/18 9:57:24
CU A-9	✓	2.1	19.5	TIA - Cat 5e Channel	2014/12/18 10:15:38
CU A-10	✓	2.6	12.6	TIA - Cat 6A Channel	2014/12/18 10:17:06
CU A-11	✗	2.6	0.1	TIA - Cat 8 Draft Channel	2014/12/18 10:17:49
CU A-1	✓	3.7	5.3	TIA - Cat 6A Permanent Link	2014/12/04 17:07:44
CU A-2	✓	3.7	6.2	TIA - Cat 6A Permanent Link	2014/12/18 16:48:31
d	✓	0	6.2	TIA - Cat 6A Permanent Link	2014/12/09 10:42:00
a	✓	0	6.2	TIA - Cat 6A Permanent Link	2014/12/18 17:24:36
CU A-1	✓	1.1	11.6	TIA - Cat 6A Channel	2014/12/01 16:05:53
CU A-1	✓	0.8	11.2	TIA - Cat 6A Channel	2014/12/01 16:53:21
CU A-1	✓	2.1	12.6	TIA - Cat 6A Channel	2015/01/08 16:36:42
CU A-2	✓	2.1	15.1	TIA - Cat 6A Channel	2015/01/09 14:48:42
CU A-3	✓	2.1	13.5	TIA - Cat 6A Channel	2015/01/13 19:43:27
CU A-4	✓	2.1	14.6	TIA - Cat 6A Channel	2015/01/14 13:35:04
CU A-5	✓	2.1	14.3	TIA - Cat 6A Channel	2015/01/14 13:35:42
CU A-6	✓	2.1	13.8	TIA - Cat 6A Channel	2015/01/14 13:36:34
CU A-7	✓	2.1	20.6	TIA - Cat 5e Channel	2015/01/14 13:47:08
CU A-8	✗	1.5	20.6	TIA - Cat 5e Channel	2015/01/14 13:48:54
CU A-9	✓	3.2	18.6	TIA - Cat 5e Channel	2015/01/14 13:52:08
CU A-10	✓	2.1	12.5	TIA - Cat 6A Channel	2015/01/26 9:41:52
CU A-11	✓	2.1	12.9	TIA - Cat 6A Channel	2015/01/27 13:25:01
a	✓	0	12.9	TIA - Cat 6A Permanent Link	2014/12/18 18:42:11
a	✓	0	12.9	TIA - Cat 6A Permanent Link	2014/12/04 17:30:29
a	✓	0	12.9	TIA - Cat 6A Permanent Link	2014/12/09 10:05:37
b	✓	0	12.9	TIA - Cat 6A Permanent Link	2014/12/09 10:20:34
c	✓	0	12.9	TIA - Cat 6A Permanent Link	2014/12/09 10:35:43
CU A-1	✓	1.1	11	TIA - Cat 6A Channel	2014/12/01 16:23:14
選択された試験結果の合計		合格	不合格	長さ (m)	
CU ツイストペア		25	2	58	